



SI Interceptor LIGHTNING PROTECTION
CERTIFICATE OF COMPLIANCE

Project Name: DHL – Area F
 Installation Completed: August, 2005
 Installation Contractor: Union Lightning Protection Installers
 Electrical Contractor: -----
 Design Style: Hybrid (S2000 Conductor)

This Certificate is to Certify that the Installation and Equipment is in Accordance with the Requirements of ERICO, Inc.
 Important Notice: This Lightning Protection System Should be Inspected at Least Once a Year.

Air Terminal	Radius of Protection (in Meters)	Invoice & Serial Number
T1 thru T8	82	SI 40

Attractive Radius is based on Protection Level II in accordance with NFC 17-102

The Accredited Representative of ERICO, Inc.

System Ground Resistance: <10 Ohms
 Depth of Ground Electrode System: 3-4 Feet
 Bonded to Building Ground: Yes (Steel)
 Mounting Support: Guyed & Side
 Lightning Event Counters Installed: Yes

